

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

No. FC/MS/DFS/08/3493  
To,

Dated: 19/12/08

The Education Officer,  
Municipal Corporation of Delhi,  
Nigam Bhawan, Kashmerigate,  
Delhi-110006

Sub: Issue of No Objection Certificate from fire safety point of view in favour of school building of DIWAN CHAND ARYA SENIOR SECONDARY SCHOOL NEW DELHI-03

Sir,

Please refer to party letter No. nil dated 01-12-08 on the subject cited above. In this regard the abovementioned school building has been inspected by concerned Assistant Divisional Officer on 15-12-08 to verify the performance of existing fire safety arrangements in the light of circular no. 262-362 dated 17-01-05 issued by education Directorate, Old Secretariat, Delhi-54. At the time of inspection Principal Dr. Sunita Chaudhary was also present.

During the course of inspection it was observed that school building is comprised of ground plus one upper floor. There are two staircases in the building from ground floor to up to terrace. The school building is abutting on main road which is approachable for fire service vehicles.

Fire safety arrangements found provided are overhead static water tank of 2500 liters, Hose reel at each floors connected to over head static water tank with proper boosting arrangement and portable fire extinguishers ISI marked found provided at each floor. Emergency telephone numbers found displayed. The system/fire fighting equipments were operated and performance was found satisfactory.


The clarification with regard to any deviation in the building structure/occupancy /stability of the building, ventilation and installation of electrical gadgets etc may be verified from the authorities concerned.

Keeping in view substantial compliance of fire safety directives as per the circular issued by the director of Education for School building, this department has no objection for the current occupancy to running a School in above said building. It is also clarified that mere providing these fire protection arrangement shall not confer any right to the owner /occupier of the building for regularization of unauthorized construction, if any, However, the following directives must be strictly adhered to :-

1. Means of escape shall not be obstructed or locked from outside and are easily open able by occupant in emergency.
2. The employees shall be acquainted with the use of fire fighting installation/ equipments.
3. All fire fighting equipments as seen during the inspection shall be available in good repairs at all time.

Any lapse rendering fire fighting equipment non functional shall be at the risk and responsibility of the management solely.

Yours faithfully



DY. CHIF FIRE OFFICER  
DELHI FIRE SERVICE

Copy to:- Principal,  
Diwan Chand Arya Senior Secondary school,  
Lodhi Colony, New Delhi-3